

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS  
D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)  
METHODE OC

## CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product  
Produit

### Switching Power Supplies

Name and address of the applicant  
Nom et adresse du demandeur

**HENGFU CORP  
CAOHEJING HIGH-TECH PARK  
470 GUI PING RD  
200233 SHANGHAI CHINA  
HENGFU CORP  
CAOHEJING HIGH-TECH PARK  
470 GUI PING RD  
200233 SHANGHAI, CHINA  
HENGFU CORP  
CAOHEJING HIGH-TECH PARK  
470 GUI PING RD  
200233 SHANGHAI, CHINA**

Name and address of the manufacturer  
Nom et adresse du fabricant

Name and address of the factory  
Nom et adresse de l'usine

Note: When more than one factory, please report on page 2  
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page

**100-240Vac, 5A, 50/60Hz, Class I  
IP X0**

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

Trademark (if any)  
Marque de fabrique (si elle existe)



Model / Type Ref.  
Ref. De type

**HF320W-SC-X,  
where X represent the output voltage and can be 3.3, 5, 7.5, 9,  
12, 13.5, 15, 24, 27, 30, 36 or 48.**

Additional information (if necessary may also be reported  
on page 2)  
Les informations complémentaires (si nécessaire, peuvent  
être indiqués sur la 2<sup>ème</sup> page)

**See appendix**

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

**PUBLICATION  
IEC 60950-1:2005**

**EDITION  
2<sup>nd</sup>**

As shown in the Test Report Ref. No. which forms part of  
this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

**E232014-A16-CB-1 issued date 2011-02-18**

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



**UL International Demko A/S**  
Lyskaer 8, P.O. Box 514, DK-2730 Herlev, Denmark  
Tel: +45 44856565, Fax: +45 44856500

Date:

2011-02-18

Signature:

**Jan-Erik Storgaard**  
Certification manager



Ref. Certif. No.

DK-21873

**Additional**

**Output:**

Model HF320W-SC-3.3: 3.3Vdc, 60.0A;  
Model HF320W-SC-5: 5Vdc, 60.0A;  
Model HF320W-SC-7.5: 7.5Vdc, 40.0A;  
Model HF320W-SC-9: 9Vdc, 33.3A;  
Model HF320W-SC-12: 12Vdc, 25.0A;  
Model HF320W-SC-13.5: 13.5Vdc, 22.2A;  
Model HF320W-SC-15: 15Vdc, 20.0A;  
Model HF320W-SC-24: 24Vdc, 13.0A;  
Model HF320W-SC-27: 27Vdc, 11.7A;  
Model HF320W-SC-30: 30Vdc, 10.5A;  
Model HF320W-SC-36: 36Vdc, 8.8A;  
Model HF320W-SC-48: 48Vdc, 6.7A.

Also investigated to EN 60950-1:2006  
for building-in

**Additional information (if necessary)**  
**Information complémentaire (si nécessaire)**



Date:

2011-02-18

**UL International Demko A/S**

Lyskaer 8, P.O. Box 514, DK-2730 Herlev, Denmark  
Tel: +45 44856565, Fax: +45 44856500

Signature:

**Jan-Erik Storgaard**  
Certification manager